



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned by Government of Karnataka undertaking)

No: EE/KMLD/AEE(O)/AE/13-14/

Ph: 080-25631801 Fax: 080-25631801

E-Mail: eeadnlsouth.work@gmail.com

Encl:

2081 - St Office of the, Executive Engineer (Elec.,)

(C,O&M), Koramangala Division,

29.6.2017

No.6, 7th Main, 80ft Road, 3rd Block, Koramangala,

Bangalore-560 034.

Sri P.H.Muniyappa &P.H.Siddappa GPA M/S Asset Handlers pvt ltd Syno 114/1, Gunjurpalya. Bangalore.

Sir,

Sub: Issue of NOC to the proposed Residential Apartment to an extent 818kw in favor of Sri P.H.Muniyappa &P.H.Siddappa GPA M/S Asset Handlers Pvt ltd Sy no 114/1, Gunjur palya, Bangalore.

Ref: 1. Letter No: AEE/S7/AET/1491/19.6.2013.

With reference to the above, "No Objection Certificate" from Koramangala Division, B'lore is hereby issued for arranging power supply to the proposed Residential Apartment to an extent of 818kw at, Sy No-114/1 Gunjur village, Bangalore in S7 sub division.

Power supply to your proposed residential apartment will be arranged with the following arrangements:

Regular Source:-

- a) It is proposed to replace the existing 11kv OH line 4 ACSR wire by coyote wire to a distance of 03KM by providing 15nos of intermediate poles from point A to B and it is proposed to extend 11kv line by using 3x400sqmm UG cable to a distance of about 0.2Km.
- b) It is proposed to provide one RMU of 2OD + 1VL inside the applicant premises.
- .1) You have to develop the infrastructure including the cost of 11KV lines etc. as mentioned above on Self- execution basis through a Government class-1 electrical contractor by paying necessary supervision charges to BESCOM duly observing BESCOM formalities.
- 2) If any KPTCL/ BESCOM lines are passing through the applicant's premises these shall be shifted at your cost. This NOC does not apply to the premises where EHT lines are passing through the premises for which NOC is to be obtained from he concerned authorities
- 3) If any installation existing, in the said premises the same shall be surrendered by clearing all arrears before taking up infrastructure work in the premises.
- 4) While applying for power supply to the above address, all rules as per KERC Electricity supply and distribution code shall be observed.

- 5) Power supply shall be arranged to the said buildings based on the provisions of regulations of BESCOM is applicable at that time
- 6) This "NOC" is issued only for the purpose of obtaining sanction plan for from BDA/BBMP/Competent authorities and is not a commitment for power sanction from BESCOM. Power supply will be sanctioned when applied for subject to feasibility at that time.
- 7) The approximate load requirement of the above residential apartment is 818kw.
- 8) This NOC is valid for a period of One Year from the date of issue.
- 9) For MS Residential building / apartments Solar Heaters should be provided with a capacity of 100 Liters either for individual flat or bulk solar water heater to be provided with suitable capacity which may be calculating 100 liters/ flat.
- 10) As per the above, if there is no sufficient space to provide Solar Water heater block of MS Residential/apartments should be provided with solar water heater of capacity 100 liters/ flat either individual or bulk solar water heater by calculating 100 liters/ flat for total No of flats on the top of the block
- 11)In future, if the requested load exceeds 4000 kVA, the Applicant have to provide prescribed space to establish a 66/11kV MUSS at free of cost to KPTCL.

The existing RRNO7SMIP-55 arrears RS 20161.00 to be paid before availing temporary power supply and the installation is to be surrendered.

Yours Faithfully

(S.T. Shanthamallappa)
Executive Engineer, Ele.
Koramangala Division,
BESCOM,Bangalore-34

Copy to:

- The Assistant Executive Engineer (El),S7 Sub Division, BESCOM,HAL Airport Road, Bangalore for Information and arrears of Rs. 20,161.00 on RR.No.7 SMIP-55, shall be collected before arranging temporary power supply to the said premises.
- 2. AE/MF

ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ ನಿಯಮಿತ, ಬೆಂಗಳೂರು BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

BANGALORE

7

ವಿದ್ಯುತ್ ಬಿಲ್ / ELECTRICITY BILL

57

Asst. Executive Engg

Sub Divn.

ಸ್ಥಳ ಸಂಕೇತ / Location Code :

1120403 1120403036027

ಗ್ರಾಹಕರ ಐ.ಡಿ. / Consumer ID : ರಿಗಿ] ಆರ್. ಆರ್. ಸಂಖ್ಯೆ / RR No. : ರಿಗಿ]

SMIPS5

ಹೆಸರು ಮತ್ತು ವಿಳಾಸ / Name and Address

RI:D:YELLAPPA 5/0 HUCHAPPA GUNJOOR PALYA

MRIP

ಮಾ.ಓ. ಸಂಕೇತ / Mtr. Rdr. Code : L ಜಕಾತಿ / Tariff Code : 2 ಓದುವ ದಿನಾಂಕ / Billing Date : 1

LT4(A)(I) 29-03-1984

ಬಲ್ಲಿನ ಸಂಖ್ಯೆ / Bill No. : 6.00 ಮಂ.ಎ. ಪ್ರಮಾಣ / Sanct. Load ಮಾರ್ಗ ಕನಿಷ್ಠ / Line Minimum : 0.00

6.00 + 0.00 0.00 0.00

0

ಸಿ.ಟಿ. ಅನುಪಾತ / CT Ratio : ಸ್ಥಾವರದ ಸ್ಥಿತಿ / Installn. Status : ಆರೆಕಾಲಿಕ/ಉಚಿತ/ FL/ Part Bill :

ಹಾಲಿ ಮಾಪನ / Pres. Rdg. : ಹಿಂದಿನ ಮಾಪನ / Prev. Rdg. : ಬಳಸಿದ ಯಾನಿಟ್ಬುಗಳು / Units Consumed: ಪವರ್ ಫ್ಯಾಕ್ಟರ್ / Power Factor :

0

ನಿಶ್ಚಿತ ಶುಲ್ಕ / FIXED CHARGES

ಪರಿಮಾನ / kW

ದರ / Rate

ಮೊತ್ತ / Amount

ಮೊತ್ತ / Amount

ವಿದ್ಯುತ್ ಶುಲ್ತ / ENERGY CHARGES

ಪರಿಮಾನ / kW ದರ / Rate

0.00

ಹೆಚ್ಚುವರಿ ದಂಡ / Penalty Chgs. : 0.00 ಸುತ್ತಿ ಮತ್ತು ನೀಡಿದ ಮಲ್ಲ / D & R Fees :

ಅಧಿಕ ಪ್ರಮಾಣ ದಂಡ / Pen. on Ex. Ld. : ಪಿ. ಎಫ್. ದಂಡ / PF Penalty : ಮೊತ್ತದ ಮೇಲೆ ತೆಂಗೆ / Tax on Amount :

0.00 0.00 20160.00

ಬಿಲ್ ಮೊತ್ತ / Bill Amount : ಬಡ್ಡಿ / Interest : ಬಾಕಿ / Arrears : ಬಾಕಿ +ಬಡ್ಡಿ / Arrs. + Interest : 1.00 0.00 1.00

ಬಾಕಿ +ಬಡ್ಡಿ / Arrs ಇತರೆ / Others ಜಮೆ / Credit 0.00

ಜಮೆ / Credit ರಿಯಾಯಿತಿ / Rebate

20161.00


ಪಾವತಿಸ ಬೇಕಾದ ಮೊತ್ತ / NET AMT. DUE :13-04-1984

ABSES 255 06/DURDATE 02:20:24 PM

Complaints? Call

Toll Free Phone No. 1800-425-2627

ಮಾಪಕ ಓದಿದವರ ಸಹಿ / Meter Reader's Sign.



Sir.

Sub: Issue of NOC to the proposed Residential Apartment to an extent 818kw in favor of Sri P.H.Muniyappa &P.H.Siddappa GPA M/S Asset Handlers Pvt ltd Sy no 114/1, Gunjur palya, Bangalore.

Ref: 1. Letter No: AEE/S7/AET/1491/19.6.2013.

With reference to the above, "No Objection Certificate" from Koramangala Division, B'lore is hereby issued for arranging power supply to the proposed Residential Apartment to an extent of 818kw at, Sy No-114/1 Gunjur village, Bangalore in S7 sub division.

Power supply to your proposed residential apartment will be arranged with the following arrangements:

Regular Source:-

- a) It is proposed to replace the existing 11kv OH line 4 ACSR wire by coyote wire to a distance of 03KM by providing 15nos of intermediate poles from point A to B and it is proposed to extend 11kv line by using 3x400sqmm UG cable to a distance of about 0.2Km.
- b) It is proposed to provide one RMU of 2OD + 1VL inside the applicant premises.
- .1) You have to develop the infrastructure including the cost of 11KV lines etc. as mentioned above on Self- execution basis through a Government class-1 electrical contractor by paying necessary supervision charges to BESCOM duly observing BESCOM formalities.
- 2) If any KPTCL/ BESCOM lines are passing through the applicant's premises these shall be shifted at your cost. This NOC does not apply to the premises where EHT lines are passing through the premises for which NOC is to be obtained from he concerned authorities
- 3) If any installation existing, in the said premises the same shall be surrendered by clearing all arrears before taking up infrastructure work in the premises.
- 4) While applying for power supply to the above address, all rules as per KERC Electricity supply and distribution code shall be observed.