

**Office of the Director General of Police**  
Commandant General, Home Guards &  
Director of Civil Defence and  
Director General Karnataka State Fire &  
Emergency Services  
No. 1, Annaswamy Mudaliar Road  
Bangalore - 560 042



Phone : 25570733  
: 22971501  
Fax : 22971512

No. GBC(1) 286/2013

13-08-2013

To  
The Commissioner,  
Bruhat Bangalore Mahanagara Palike,  
N.R. Square,  
Bangalore – 560 002.

Sir,

Sub: Issue of No Objection Certificate for the construction of High Rise Residential Building at Khatha No. 751, Sy. No. 114/1, Municipal No. 145, Gunjur Village, Varthur Hobli, Ward No. 149, Bangalore.

Ref: Letter dated 5-6-2013 of the Authorised Signatory,  
M/s Asset Handlers Pvt. Ltd., No. 476, 2<sup>nd</sup> floor, 80 feet Road,  
6<sup>th</sup> Block, Koramangala, Bangalore – 560 095.

\*\*\*\*\*

With reference to the letter of the Authorised Signatory, M/s Asset Handlers Pvt. Ltd., cited above, the Regional Fire Officer, Bangalore East Range, Bangalore of this department has inspected the site of proposed High Rise Residential Building, comprising of Ground & 6 upper floors at Khatha No. 751, Sy. No. 114/1, Municipal No. 145, Gunjur Village, Varthur Hobli, Ward No. 149, Bangalore on 14-6-2013 with reference to the drawings, submitted by the applicant and has furnished the details as follows :-

**A, Details of the premises.**

01. Address of the premises : Khatha No. 751, Sy. No. 114/1,  
Municipal No. 145,  
Gunjur Village,  
Varthur Hobli,  
Ward No. 149,  
Bangalore.
2. Number of Buildings : One Building.

3. Number of floors : Ground & 6 upper floors.
4. Type of Occupancy : Residential.
5. Floor wise details of the occupancy :-
- Ground floor : For parking 119 Cars, 1 Electrical Room & 1 D. G. Room.
- 1<sup>st</sup> floor to 6<sup>th</sup> floor : 25 flats on each floor x 6 floors = 150 flats.
- Total : 150 flats.**
6. Height of the Building : 20.40 mtrs.
7. Site Area : 8,147.00 Sq. mtrs.
8. Built-up area of each floor :-
- Ground floor to 6<sup>th</sup> floor : 22,593.97 Sq. mtrs.  
(3227.71 Sq. mtrs. on each floor x 7 floors)
9. Total Built-up area : 22,593.97 Sq. mtrs.
10. Surrounding properties:-
- East : Vacant land
- West : Vacant land.
- North : Vacant land,
- South : 12.05 mtrs. wide Gunjur Road.



**B. The plan shows the following structural details indicating the fire prevention, fire fighting and evacuation measures. These measures are considered adequate as follows:-**

Details (1)	Existing (2)
1. Width of the road to which the building abuts and whether it is hard surfaced to carry the weight of 45,000 kgs.	: The premises is abutting 12.05 mtrs. wide Gunjur Road, located on the southern side. The road is hardened to carry the weight of 45,000 kgs.
2. Number of entrances and width of each	: Proposed to provide one entrance of 6.00 mtrs. width with entry & exit from 12.05 mtrs. wide Gunjur Road, located on the southern side.
3. Height clearance over the entrance	: No arch or any other constructions has been proposed over the entrance.
4. <u>Width of open space (Setbacks):-</u>	
Front (South)	: Minimum 8.01 mtrs.
Rear (North)	: Minimum 7.69 mtrs.
Side (East)	: Minimum 7.00 mtrs.
Side (West)	: Minimum 9.93 mtrs.
5. Arrangement for parking the Cars	: Provision has been made to park 119 Cars at ground floor parking area & 45 Cars on the open space available all around the Building. This setback parking shall be after leaving 6.00 mtrs. wide driveway from the building line.
6. Number of Staircases	: 4.



(1)	(2)
7. Location of the staircases	All the staircases have been designed to abut one of its side to the external wall. Further provision has been made to enclose all the staircases at each floor level.
8. <u>Staircase size:-</u>	
(a) Width of the staircases	3 each of 1.20 mtrs. & another of 1.70 mtrs.
(b) Width of treads	30 Cms.
(c) Height of riser	15 Cms.
(d) Number of risers in a flight	9 risers per flight.
(e) Height of hand rails	1.00 mtr. As proposed, the hand rails should be provided at a height of 1.00 mtr. The gap between two verticals should not exceed 15 cms.
(f) Head room clearance	Minimum 2.40 mtrs.
9. Travel distance from the farthest point and from dead-end of the corridor to the staircase.	Maximum 22.45 mtrs. from the farthest point and maximum 11.20 mtrs. dead end of the corridor to the staircases.
10. Number of lifts and capacity	3 lifts , each of 8 passengers capacity.

**C. While constructing the building the following fire safety measures should be incorporated:-**

Details (1)	Existing (2)	Recommendation (3)
1. Condition of the open space.	--	Out of the allowed & required setbacks of minimum 7.00 mtrs. all around the Building, setbacks to an extent of 6.00 mtrs. from the Building line should have a RCC slab of 200 mm thickness to carry the load of 45,000 kgs., being the weight of a fire unit. This driveway all around the building, should



(1)	(2)	(3)
		<p>always be kept free and clear. It would be advantageous to the builders and the users to elevate this portion by a few inches and even provide for a different colour, so that people are aware that this is the emergency route for fire fighting vehicles, ambulances etc. The total setbacks shall be at even level without any structure and projections up to a height of 5.00 mtrs. These setbacks shall be always kept free from any construction or utilization like garden, landscaping parking etc.</p>
2. Structural materials.	---	<p>RCC materials and brick walls of not less than two hours fire resistance should be used for the construction of structures. Only fire resistant materials or materials treated with fire retardant chemicals, should be used for interior decoration work. While attending the interior decoration the fixed fire fighting systems like sprinklers/risers etc., should not be covered or shifted from their original location.</p>
3. Design of the staircases.	Not indicated	<p>All the staircases should be constructed with non-combustible materials and should be completely enclosed at each landing to prevent smoke and fire traveling from the lower floors to the upper floors. Enclosures to staircases should be provided with self-closing smoke-stopping swing-door, fitted with door closing devices at the exit to the lobby. These doors should have at least two hours fire resistance capacity. The staircase area should be without glazing or glass brick walls to avoid reflections. Any area of dwelling or storage should not open directly to the staircase.</p>



(1)	(2)	(3)
4. Specification of lift.	Not indicated	<p>The brick walls, enclosing the lift shafts, should be of 90 mm thickness and have a fire resistance of not less than two hours. Shaft should have permanent vent of not less than 0.2 sq. mtrs. clear area, immediately under the machine room. Lift motor rooms should be preferably located at the top of the shaft and separated by the enclosing wall of shaft or by the floor of the machine room. Landing doors of lift enclosures should open into a ventilated lobby having one hour fire resistance. Lift car doors should be of metal finish, operating automatically and should have fire resistance capacity of one hour. Exit from the lift lobby should be through a self closing smoke stopping door of 15 mm thickness, having one hour fire resistance capacity. This is to prevent smoke and fire traveling from the lower floors to the upper floors. The lift machine rooms should be separate and no other machinery should be installed therein. Each lift should be connected to an alternative source of power (generator). Grounding switches at the ground floor level to enable the Fire &amp; Emergency Services personnel to ground all the lift cars and use them as ' FIRE LIFT' in an emergency should be provided.</p>
5. Service ducts/shafts.	---	<p>Service ducts should be enclosed by walls of 100 mm. thickness to have at least two hrs fire resistance capacity. A vent, opening at the top of the service shafts, should be provided between one fourth and half of the area of the shafts. The electrical distribution cables and wiring should be laid in a separate duct. All the ducts should be sealed at every alternate floor with non-combustible metal doors having at least two hours fire resistance capacity.</p>



(1)	(2)	(3)
		<p>Water mains, telephone lines, intercom lines or any other service lines should not be laid in the duct, meant for electric cables.</p> <p>The inspection panel doors and any other opening to the shafts should be provided with airtight doors of at least two hours fire resistance capacity.</p>
6. Escape route.	Not indicated	<p>Direction in which the inmates should have to move in the event of any emergency have to be indicated in the corridor/passage on each floor as a guide during evacuation. These marking should be in luminous paint.</p>

**D. The builder should arrange for the following fire fighting and evacuation measures:-**

Details (1)	Existing (2)	Recommendation (3)
1. Electric power supply.	---	<p>Circuits for water pumps, lifts, staircase lighting in the building should be by separate line and independently connected so that they can be operated by one switch installed the ground floor. Dual operated switches should be installed in the service room for terminating the standby supply.</p> <p>As proposed one standby generator of 100 KVA capacity shall be installed at Ground floor to supply alternative power for staircase lighting, corridor lighting, fire fighting systems and lifts etc., in the event of failure of electricity supply, in the building.</p>



(1)	(2)	(3)
2. Wet riser-cum-	Proposed to provide 4 down comer systems.	<p>As proposed 4 down comer systems, near each staircase shall be provided. Each down comer should be of 100 mm internal diameter and of G.I. 'C' Class pipe. From each down comer single hydrant outlets should be provided at each landing. Hose reel hose of minimum 19 mm size of adequate length to reach the farthest point of each floor should be provided with a shut off branch having a nozzle of 5 mm size. The hose reel hose should be connected at each landing by means of an adaptor. Adequate B.I.S. marked reinforced rubber lined delivery hoses of 63 mm size to reach the farthest point of the floor/setbacks from the system should be provided with a branch pipe near each hydrant outlet (both internal and external) in a proper box to protect it from withering. At least two fire service inlets to boost the water in the riser directly from the mobile pump should also be provided. These inlets should be located at an easily accessible position, preferably near the entry point to the premises.</p> <p>Each down comer system should be connected to an overhead tank of 25,000 litres capacity with an electrically driven pump, capable of delivering 900 litres of water per minute at 3N/mm<sup>2</sup> pressure (total 4 overhead tanks &amp; 4 booster pumps). The impeller of all the pumps should be made of bronze.</p>
3. Manually operated fire alarm system	Proposed to provide manually operated electrical fire alarm	Manually operated electrical fire alarm system should be installed with call boxes located near each staircase landing. The call boxes should be of "break glass" type, where the call is transmitted





(1)	(2)	(3)
	system with call boxes near each staircase landing.	automatically to the control room when the glass of the system is broken. This system should also be connected to an alternative source of power supply (diesel generator). The call boxes should be so installed that their location can be easily noticed from either direction and should be at a height of one meter from the floor level.
4. Automatic sprinkler system.	Proposed to provide automatic sprinkler system with 188 sprinkler heads at Ground floor parking area.	Adequate. The sprinkler system shall be connected to down comer systems.
5. Public address system.	Proposed to provide public address system with two way communication facility.	As proposed a public address system with two way communication facility should be provided at each floor near each staircase landing with its console at the control room, located on the ground floor.
6. Assembly Area	Not marked.	An area at an appropriate place in the allowed/ required setbacks shall be earmarked with a proper board as 'ASSEMBLY AREA' for the occupants to assemble after evacuation during practice drill and in an emergency.
7. Portable fire extinguishers.	Proposed to provide suitable type of portable fire extinguishers as per the requirements	<p>a) One ABC Powder extinguisher of 5 kgs. capacity at ground floor parking area and also on the open space parking area under shelter.</p> <p>b) One ABC extinguisher of 2 kgs. capacity should be provided near the entrance to each main switch board room, inside each lift machine room &amp; inside each Kitchen.</p>



(1)

(2)

(3)

c) One ABC Powder extinguisher of 5 kgs. capacity should be provided near the transformer, if installed & near the entrance of D. G. Room.

e) One ABC Powder extinguisher of 5 kgs. capacity should be kept near each staircase landing on every floor.

e) All the extinguishers suggested above should be with B.I.S. markings and should be located at an easily accessible position without obstructing the normal passage.

8. Fire safety plan.

---

A Fire safety plan for preventing and extinguishing any accidental fire in the Building and action to be taken by the occupants in case of such fire should be prepared in advance and got approved by the Director, Karnataka Fire & Emergency Services. The fire safety plan, so approved, should contain the telephone numbers of the nearest Fire Control i.e., 101, 22971500, 22971550 and 22971600. The plan should be distributed to all the occupants and employees in the building and should be displayed on every floor.

A Fire Command Station should be established in the lobby of the Building on the entrance floor and such command station should be adequately illuminated. The main control of the public address system and fire alarm system should be at the Fire Command Station.



(1)	(2)	(3)
9. Training	Not indicated	<p>A Fire Safety Director should be nominated for the Building. He should conduct fire and evacuation drills periodically. He should nominate a Fire Warden for each floor and ensure that no individual of the building does anything which causes or stimulates an accidental fire and in case of lapses in respect of fire prevention measures, he should take action as deemed fit to ensure the safety from the fire point of view. If the action is beyond his capacity he should inform the Fire &amp; Emergency Services department.</p> <p>40% of the occupant/employees should be got trained in fire prevention &amp; fire fighting at the R.A. Mundkur Fire &amp; Emergency Services Academy. Bannerghatta Road, Bangalore – 560 029. within 6 months from the date of occupation of the building. For this purpose, before approaching this department for final clearance certificate, the applicant should give an undertaking in the form of an affidavit regarding the maintenance of the fire prevention and fire fighting measures suggested above and arranging training of 40% of the occupants in fire prevention and fire fighting within 6 months from the date of issue of the clearance certificate.</p>

**E. General:-**

- 1) All the fire prevention, fire fighting and evacuation measures suggested / recommended in B, C & D shall be strictly adhered to adopted.
- 2) Hazardous materials such as petroleum products, explosives, chemicals etc. should not be stored on any floor of the building.



- 3) Refuse dumps or storage should not be permitted in any of the floors.
- 4) Liquefied petroleum gas should not be stored in the building, except limited quantity required for each kitchen.
- 5) Plan & occupancy should not be changed without informing the Fire & Emergency Services and without taking clearance.
- 6) The occupancy certificates should not be issued without obtaining the clearance certificate from the Fire & Emergency Services department as per Chapter 3.16 (v) of the Zoning Regulation 2007 of the Bangalore Development Authority.
- 7) Such reasonable changes/modifications as may be found necessary, after the building is fully constructed, will have to be agreed to be done by the builder/occupants of the building.
- 8) All the metal fittings of down comer system and all the extinguishers suggested above should have B.I.S markings.

Subject to the strict adherence to the conditions laid down as above, issue of license for the construction of High Rise Residential Building at Khatha No. 751, Sy. No. 114/1, Municipal No. 145, Gunjur Village, Varthur Hobli, Ward No. 149, Bangalore may please be considered.



Yours faithfully

*[Signature]*  
 Director General of Police  
 and Director General,  
 Karnataka Fire & Emergency Services.

✓ Copy to: 1) The Authorised Signatory, M/s Asset Handlers Pvt. Ltd., No. 476, 2<sup>nd</sup> floor, 80 Feet Road, 6<sup>th</sup> Block, Koramangala, Bangalore – 560 095.

2) The Regional Fire Officer, Bangalore East Range, Bangalore.